

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### Sewage spill incidents (Beach closures, and spills of 500 gallons and above)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
5/10/01	5/10/01	15469	Private Party	7000 Katella, Stanton, Orange County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a broken private lateral. All 1,500 gallons of the spill were contained, recovered, and returned to the operational sewer system. City of Stanton staff repaired the lateral, cleaned up, and disinfected the affected area.
5/7/01	4/30/01	13324	City of Riverside	3520 Central Ave., Riverside, Riverside County	SSO	600	An estimated 600 gallons of sewage overflowed from a manhole due to unspecified blockage. Approximately 200 gallons of the spill were contained and returned to the sewer system while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City staff.
5/9/01	5/5/01	11963	EMWD	Rowe Dr. and Cocktail Dr., Moreno Valley, Riverside County	SSO	1,650	An estimated 1,650 gallons of sewage overflowed from a manhole due to grease blockage of 8" sewer main. All the spill was contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up and disinfected by EMWD's staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### Sewage spill incidents (Beach closures, and spills of 500 gallons and above)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
6/9/01	6/9/01	15467	Westgrove Shopping Center	8600 Westminster Blv., Westminster, Orange County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a private manhole at Westgrove Shopping Center due to a grease blockage. None of the spill was contained or recovered. It discharged into a local storm drain and flowed to Westminster Channel. Due to this sewage spill OCHCA closed the harbor water area at Sunset Aquatic Park and Portofino Cove in Huntington Harbor to swimming and diving. City of Huntington Beach staff assisted the City of Westminster staff in unblocking the sewerline, cleaning up, and disinfecting the affected area.
6/11/01	6/11/01	13978	Private Party	7611 Slater Ave., Fountain Valley, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private party's lateral. 100 gallons of the spill were contained, recovered, and returned to the operational sewer system. 400 gallons of the spill were not recovered and discharged into a local storm drain which ended in Talbert Lake. The blockage was removed, the affected area was cleaned up and disinfected by the City of Fountain Valley staff.
6/24/01	6/23/01	13980	Pan Pacific Retail Properties	5735 East La Palma, Anaheim, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from a private party's manhole due to debris accumulated in the sewerline. None of the spill was recovered and it discharged into a local storm drain. a private contractor removed the blockage and cleaned up the affected area.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### Sewage spill incidents (Beach closures, and spills of 500 gallons and above)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
6/30/01	6/30/01	14005	City of Ontario	1900 Riverside Dr., Ontario, San Bernardino County	SSO	7,000	An estimated 7,000 gallons of sewage overflowed from a wet well at the Whispering Lake lift station due to a power outage. All 7,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The lift station's power was restored, the affected area cleaned up, and disinfected by Ontario City staff.
7/8/01	7/8/01	14008	Jurupa Community Service Dist.	Corner of Etiwanda Ave & Limonite, Jurupa, Riverside County	SSO	500	An estimated 500 gallons of sewage was released from an air relief valve due to a mechanical failure of the valve. All 500 gallons of the spill were contained in the storm drain, recovered, and returned to the operational sewer system. The valve was repaired, the affected area cleaned up, and disinfected by JCSD's staff.
7/10/01	7/2/01	13877	Private Party (Glenwood Apart)	145 South Western Ave., Anaheim, Orange County	SSO	9,800	An estimated 9,800 gallons of sewage leaked from a broken private lateral. 8,200 gallons of sewage discharged into a local storm drain which lead OCHCA to close a portion of Seal Beach from San Gabriel River to the projection of 4th Street. 1,600 gallons of the spill were contained, recovered, and returned to the operational sewer system. The damaged sewerline was repaired, the affected area cleaned up and disinfected by the City of Anaheim staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### Sewage spill incidents (Beach closures, and spills of 500 gallons and above)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/11/01	6/8/01	13960	Private Party (Seafood Paradise)	8602 Westminster Blv. Westminster, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from an oil and grease trap at the Seafood Paradise restaurant. All 500 gallons of the spill were contained, recovered, and returned to the operational sewer system. City of Westminster staff assisted the private party in clearing the blockage, cleaning up, and disinfecting the affected area.
7/11/01	6/25/01	13959	Private Party	John F. Kennedy & Championship Dr., Moreno Valley, Riverside County	SSO	46,000	An estimated 46,000 gallons of sewage overflowed from a manhole due to construction debris. All 46,000 gallons of the spill were contained in three ponds constructed by the contractor at the site. EMWD recovered and returned all the contained sewage spill into the operational sewer system. The blockage was cleared, the affected area disinfected, and cleaned up by EMWD's staff.
7/12/01	6/23/01	14004	Save-On Drugs/ Pacific Retail Property	5735 East La Palma, Anaheim, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from a private lateral due to oil/grease blockage. All 600 gallons of the spill discharged into a local storm drain. The blockage was removed, the affected area cleaned up, and disinfected by the City of Anaheim staff.
7/12/01	6/27/01	13998	Balboa Yacht Club	Balboa Yacht Club, Newport Beach, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from the Balboa Yacht Club's manhole due to oil/grease blockage. All the spill discharged into the bay and none of it was recovered. A private contractor removed the blockage, cleaned up the affected area, and disinfected.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### Sewage spill incidents (Beach closures, and spills of 500 gallons and above)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/12/01	6/28/01	14000	Private Party	8113 Cerritos Ave., Stanton, Orange County	SSO	4,500	An estimated 4,500 gallons of sewage overflowed from a private lateral due to unknown cause. 3,500 gallons of the spill were contained, recovered, and returned to the operational sewer system. 1,000 gallons of the spill were not recovered and discharged into a local storm drain which flowed to Stanton Channel. City of Stanton Public Works removed the blockage, cleaned up, and disinfected the affected area.
7/13/01	7/13/01	15426	Riverside Water Quality Control Plant	5950 Acorn Street (in the plant), Riverside, Riverside County	SSO	575	An estimated 575 gallons of sewage overflowed between primary clarifiers # 6 and # 7 in the plant due to check-valve failure. The entire quantity of the spill was contained in the plant premises. The spill did not reach, or impact the waters of the State. The entire spill percolated in a grassy area between two primary clarifiers.
7/18/01	7/14/01	15430	Orange Landfill	Orange Landfill (Bee Canyon), Orange, Orange County	TTRW	1.08MG	An estimated 1.08 million gallons of tertiary treated reclaimed water (TTRW) were released due to a broken line. This release was going on for five days. The reclaimed water system is owned and operated by Orange County for landfill operations, and is used for irrigation, soil compaction, and dust control. IRWD's staff assisted Orange County in repairing the broken line. Most of the spill discharged into San Diego Creek.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### Sewage spill incidents (Beach closures, and spills of 500 gallons and above)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/19/01	7/19/01	15413	City of Colton	Colton Plant, Colton, San Bernardino County	WW	---	An unknown amount of high chlorine residual wash water (3mg/L) discharged from a one-inch wash water ( WW) line at a 90-degree fitting. High residual chlorine wash water flowed into the flood control channel adjacent to the plant. No wash water made it to the Santa Ana River. The wash water percolated at the base of the flood control channel.
7/21/01	7/21/01	15414	Private Party, Apartment Complex	1136 Blaine Street, Riverside, Riverside County	SSO	500	An estimated 500 gallons of sewage overflowed from a private manhole of an apartment complex due to a grease blockage. Only 10 gallons of the spill were recovered and returned to the operational sewer system. 490 gallons of the spill were discharged into a local storm drain where it percolated. City of Riverside staff assisted contracted plumber in clearing the sewer line, cleaning up, and disinfecting the affected area.
7/24/01	7/23/01	15407	Private Party	2900 Bristol Street, Costa Mesa, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private manhole due to equipment failure at a private pump station. None of the 500 gallons of the spill were recovered and it discharged into a local storm drain. Costa Mesa Sanitary District flushed the storm drain with 3,000 gallons of fresh water from the fire hydrant. The equipment was repaired, the affected area cleaned up, and disinfected by CMSD's staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### Sewage spill incidents (Beach closures, and spills of 500 gallons and above)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/29/01	7/29/01	15427	City of Anaheim	898 South Anaheim Blv., Anaheim, Orange County	SSO	910	An estimated 910 gallons of sewage overflowed from a manhole due to a blockage caused by vandalism. 510 gallons of the spill were contained, recovered, and returned to the operational sewer system. The rest of the spill was not recovered and it discharged to a local storm drain which flowed to Anaheim Barber Channel. The blockage was removed, the affected area cleaned up, and disinfected by City of Anaheim staff.
7/31/01	7/31/01	15432	Inland Empire Utilities Agency	10037 E. 8th Street, Rancho Cucamonga, San Bernardino County	CW	750	An estimated 750 gallons of cooling water (CW) discharged from a manhole due to the damage of the sealing of the manhole cover. All 750 gallons of the spill were contained, recovered, and returned to the operational sewer system by Rancho Cucamonga Water District staff. The manhole sealing cover was repaired and the affected area cleaned up by IEUA staff.
8/3/01	8/3/01	15411	City of Perris	Mildred Street & Ruby Drive, Perris, Riverside County	SSO	900	An estimated 900 gallons of sewage overflowed from a manhole due to an 8" sewer line blocked with grease. Most of the spill was contained, recovered, and returned to the operational sewer system. A small part of the spill discharged into a dry storm drain where it percolated. The blockage was cleared, the affected area cleaned up, and disinfected by the City of Perris staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### Sewage spill incidents (Beach closures, and spills of 500 gallons and above)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
8/12/01	8/12/01	15406	City of Fullerton	201 East Bastanchury, Fullerton, Orange County	SSO	6,000	An estimated 6,000 gallons of sewage overflowed from a manhole due to grease blockage. 200 gallons of the spill were recovered and returned to the operational sewer system. The remainder of the spill discharged into a local storm drain, flowed to Brea Creek Channel and then to the ocean. OCHCA closed the ocean water area from the San Gabriel River mouth to 300 feet down-coast of San Gabriel River in Seal Beach to swimming, surfing, and diving due to this sewage spill. The blockage was cleared, the affected area cleaned up, and disinfected by the City of Fullerton staff.
8/12/01	8/12/01	15409	City of Huntington Beach	12th. Street & Pacific Coast Highway, Huntington Beach, Orange County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a broken 8" forcemain. All 2,000 gallons of the spill were discharged into a local storm drain and flowed to the harbor. This spill caused the OCHCA to close the harbor water area at 11th. Street Beach, Admiralty Drive, Peter's Landing Marina, and Sunset Aquatic Marina in Huntington Harbor to swimming and diving. The sewer line was repaired, the affected area was cleaned up, and disinfected by Huntington Beach City staff.





## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### Sewage spill incidents (Beach closures, and spills of 500 gallons and above)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
8/21/01	8/20/01	16059	DJ's Restaurant	16060 Beach Blv, DJ's Restaurant, Huntington Beach, Orange County	SSO	750	An estimated 750 gallons of sewage overflowed from a grease trap at a private restaurant. 700 gallons of the spill were contained, recovered, and returned into the operational sewer system. Only 50 gallons of the spill were not recovered and discharged to a local storm drain. The grease blockage was removed, the affected area cleaned up, and disinfected by the contractor with assistance of Huntington Beach staff.
8/23/01	8/23/01	15989	Harbor Patrol, Newport Beach, Orange County	1901 Bayside Dr. Newport Beach, Orange County	SSO	50	An estimated 50 gallons of sewage released from 4" PVC sewerline at vessel sewage pump out station into the Bay. The sheriff's department was conducting a dye test to determine if there were any leaks in the line. The test revealed that the line was leaking. OCHCA closed the harbor the water area at Harbor Patrol Beach in Newport Bay to swimming and diving due to this spill. A private contractor repaired the sewerline and the affected area was posted.
8/24/01	8/24/01	16005	Crow's Nest Marina, Newport Beach, Orange County	2801 W Pacific Coast HWY, Newport Beach, Orange County	SSO	50	An estimated 50 gallons of sewage released from a broken 4" PVC sewerline at vessel sewage pump out station into the Bay. OCHCA closed the harbor water area at Crow's Nest Marina in Newport Bay to swimming and diving due to this sewage spill. A private contractor repaired the sewerline and the affected area was posted.